

BOARD OF TRUSTEES OF COMMUNITY COLLEGE DISTRICT NO. 508
County of Cook and State of Illinois

EMERGENCY LIGHTING SYSTEMS CODE COMPLIANCE WORK
ALL COLLEGES AND DISTRICT OFFICE

THE CHANCELLOR

REPORTS

that it is necessary to provide a safe environment at CCC facilities by complying with new requirements of the Chicago Electrical Code to have emergency lighting systems on a power source other than electrical utility providers, for which most CCC facilities currently do not comply; and

that it is necessary to design and install emergency generators or inverter systems at Daley (old campus buildings), Olive-Harvey (old campus buildings) and Truman (Phase II Building) Colleges; Dawson Technical Institute; Lakeview, South Chicago and West Side Learning Centers; and District Office, and to test and repair existing generators and automatic transfer switching systems at Daley (main building), Olive-Harvey (main building), Truman (Phase I Building) and Wright Colleges; and

that it is cost effective and in the best interests of CCC to include this required work in the CDB managed Districtwide Electrical Systems Upgrade Project, which is currently being planned and is in contract document stage; and

that the CDB's Engineer of Record has estimated that work related to complying with emergency lighting code requirements will amount \$1,100,000; and

that immediate action is requested to provide safe environments at CCC facilities and to comply with City code requirements.

THE CHANCELLOR


RECOMMENDS

that the Board of Trustees authorize Administrative Services to expand the scope of the current CDB managed Districtwide Electrical Systems Upgrade Project to include the Emergency Lighting Code Compliance Work, increasing CCC's share of the cost of the current project by \$1,100,000.

FINANCIAL

\$1,100,000 -- Unexpended PBC Funds

Respectfully submitted:



Wayne D. Watson
Chancellor

August 6, 2003

WB
8/5/03